



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0553:0111
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	SPACE AGE ELECTRONICS 58 Chockett Road, Sterling, MA, 01564 Contact: Scholl, Robert (508) 485-0966 (508) 485-4740 Email: bob.scholl@1sae.com
DESIGN:	Models MBC and BCA battery cabinet enclosures. Minimum thickness .064" cold rolled steel, for batteries with a combined peak voltage of 42.4v. Refer to listees data sheets, installation instructions, and manufacturer's drawings for detailed product description, installation, and operational considerations.
RATING:	
INSTALLATION:	In accordance with listees printed installation instructions, applicable codes and standards, and in a manner acceptable to the Authority Having Jurisdiction.
MARKING:	Listees name, model number, use of product, and UL label.
APPROVAL:	Listed as a fire alarm equipment battery cabinet enclosure for use with listees fire alarm equipment. Refer to listees installation instruction manual for details.
NOTES:	

02-09-16 dc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/22/2023

Listing Expires: 06/30/2024

Authorized By: **Jeff Schwartz**, Program Coordinator
Fire Engineering & Investigations Division