



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-1004:0110
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Apollo America Inc. 30 Corporate Drive, Auburn Hills, MI, 48326 Contact: Howells,Dale (248) 563-8405 (248) 332-8807 Email: dale.howells@apollo-fire.com
DESIGN:	Models MR-600, MR-700, MR-800 series relay modules. MR-600 series employs manual override relays. All modules employ suffix C (Grey enclosure) or C/R (Red enclosure). Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	MR-600 series = coil voltage: 24V dc or 24 V ac MR-700 series = coil voltage: 12 V dc or 24 V dc MR-800 series = coil voltage: 24 V dc or 24 V ac or 120 V ac
INSTALLATION:	In accordance with listee's printed installation instruction, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as relay modules for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	1. Formerly Air Products and Controls, Inc.

09-09-2004



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/13/2023

Listing Expires: 06/30/2024

Authorized By: **Jeff Schwartz**, Program Coordinator
Fire Engineering & Investigations Division