



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7300-1004:0111									
<b>CATEGORY:</b>	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES									
<b>LISTEE:</b>	Apollo America Inc. 30 Corporate Drive, Auburn Hills, MI, 48326 Contact: Howells,Dale (248) 563-8405 (248) 332-8807 Email: dale.howells@apollo-fire.com									
<b>DESIGN:</b>	<p>SC-110 series fuse modules provide two fuse circuits. This series consists of SC-111, SC-112, SC-114, and SC-118.</p> <p>SC-200 series diode module provide three diode circuits. This series consists of SC-201, SC-202, SC-204, and SC-208.</p> <p>MR-310 Series relay modules provide single pole, double throw contacts. This series consists of MR-311, MR-312, and MR-313.</p> <p>MR-320 series relay modules provide double pole, double throw contacts. This series consists of MR-321, MR-322, and MR-323.</p> <p>All modules may employ suffix S (spacer mounted), T (track mounted), C (steel grey enclosure), or C/R (steel red enclosure).</p> <p>Refer to listee's data sheet for detailed product description and operational considerations.</p>									
<b>RATING:</b>	<table> <tr> <td>SC-100 series</td> <td>=</td> <td>250 VAC, 10A</td> </tr> <tr> <td>SC-200 series</td> <td>=</td> <td>1A</td> </tr> <tr> <td>MR-310 &amp; MR-320 series</td> <td>=</td> <td>120 VAC, 10A, &amp; 24 VDC, 7A</td> </tr> </table>	SC-100 series	=	250 VAC, 10A	SC-200 series	=	1A	MR-310 & MR-320 series	=	120 VAC, 10A, & 24 VDC, 7A
SC-100 series	=	250 VAC, 10A								
SC-200 series	=	1A								
MR-310 & MR-320 series	=	120 VAC, 10A, & 24 VDC, 7A								
<b>INSTALLATION:</b>	In accordance with listee's printed installation instruction, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.									
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.									
<b>APPROVAL:</b>	Listed as control unit accessories for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.									
<b>NOTES:</b>	1. Formerly Air Products and Controls, Inc.									

11-04-2004



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/13/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Jeff Schwartz**, Program Coordinator  
Fire Engineering & Investigations Division