



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-1004:0113
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Apollo America Inc. 30 Corporate Drive, Auburn Hills, MI, 48326 Contact: Howells,Dale (248) 563-8405 (248) 332-8807 Email: dale.howells@apollo-fire.com
DESIGN:	SC-310 series timing relay modules. This series consists of SC-311 and SC-314. SC-410 series sequencing relay modules. This series consists of SC-411 and SC-414. All modules may employ suffix T (track mounted), C (steel grey enclosure), or C/R (steel red enclosure). Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	SC-310 series Contacts - Resistive: 5A @ 30VDC,120VAC,240VAC 1/8HP @ 250VAC Inductive: 1.5A @ 24VAC, 120VAC, 240VAC Power: 150W, 1200VA Input Control Voltage - 12VAC/VDC @ 60mA, 24VAC/VDC @ 60mA SC-410 series Contacts - Resistive: 5A @ 30VDC,120VAC,240VAC 1/8HP @ 250VAC Inductive: 1.5A @ 24VAC, 120VAC, 240VAC Power: 150W, 1200VA Input Control Voltage - 12VAC/VDC @ 60mA, 24VAC/VDC @ 60mA
INSTALLATION:	In accordance with listee's printed installation instruction, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as control unit accessories for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	1. Formerly Air Products and Controls, Inc.

09-08-2005 jw



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/13/2023

Listing Expires: 06/30/2024

Authorized By: **Jeff Schwartz**, Program Coordinator
Fire Engineering & Investigations Division